



HAMPTON FIRE/RESCUE

A Tradition of Service, Courage and Pride

APPLICATION FOR UGST REMOVAL

(Permit Fee \$25.00 payable to Town of Hampton)

Use this application to remove, abandon or place temporarily out of service any stationary tank(s) for the storage of flammable or combustible liquids and shall be accompanied with the following information:

- a. Site plan showing property building(s), lot lines and tank location.
- b. Tank size, age and type of product that was stored in the tank(s).
- c. Name of qualified person at the job site and in writing state education or specialized training and of contents in NFPA Standards 326 and 327. (Copy of certificates preferred)
- d. Barricades and warning signs reading "FLAMMABLE - NO SMOKING" onsite.
- e. Minimum of two portable fire extinguishers each having a rating not less than 80 B.C., with a current inspection tag.
- f. Use of appropriate combustible gas detector and written log kept for this job.
- g. Location where tank(s) will be discarded.
- h. Copy of closure report forwarded to this office within 6 months of removal.

All work shall conform to minimum requirements as outlined by NFPA 30, NPFA 1, NFPA 326 and/or NFPA 327, editions as adopted by NH State Fire Code SAF-C-6000 and local ordinance.

THIS IS NOT A PERMIT: No work shall begin until a permit has been issued by this Department and all inspection requests require a 48 hour minimum notice.

Name / Address of Job Site: _____

Name / Address / Telephone & Fax # of Company: _____

For Office Use: Date Rec'd: _____ Check #: _____ Permit #: _____

HFD/300-44

64 Ashworth Avenue Hampton, NH 03842

www.hamptonfirerescue.com

Headquarters (603) 926-3316

Fax (603) 929-1915

Fire Prevention Fax (603) 926-8731



HAMPTON FIRE/RESCUE

A Tradition of Service, Courage and Pride

The following information and documentation must be provided with the application before UGST REMOVAL PERMIT can be issued.

All work shall conform to minimum requirements as outlined by NFPA 1, NFPA 30, NFPA 326 and/or NFPA 327 editions as adopted by NH State Fire Code SAF-C-6000 and local ordinances.

UGST REMOVAL	v
1. Site plan showing property building (s), lot lines and tank location.	
2. Tank size, age and type of product that was stored in the tank (s).	
3. Name of qualified person at the job site and in writing state education or specialized training and of contents in NFPA Standards 326 and 327. (Copy of certificate preferred)	
4. Barricades and warning signs reading "FLAMMABLE-NO SMOKING" on site.	
5. Minimum of two portable fire extinguishers each having a rating not less than 80 B.C. with a current inspection tag.	
6. Use of appropriate combustible gas detector and written log kept for this job.	
7. Location where tank (s) will be discarded	
8. Copy of closure report forwarded to this office within 6 months of removal.	