



HAMPTON FIRE/RESCUE

A Tradition of Service, Courage and Pride

APPLICATION TO INSTALL A FLAMMABLE OR COMBUSTIBLE LIQUIDS UNDERGROUND STORAGE TANK

All work shall comply with NFPA 30 Flammable and Combustible Liquids Code and NFPA 1 Uniform Fire Code, (editions as adopted by NH Fire Code SAF-C-6000 and local ordinance).

This application is to install, repair, or alter any stationary tank(s) for the storage of flammable or combustible liquids and shall be accompanied by a general description of the proposed work. It shall also include one copy of a drawing indicating location, use, capacity and piping arrangement of all existing and proposed tank locations, or which are to be located upon the premises and all adjacent buildings and property lines.

The Bureau of Fire Prevention requires a letter from the New Hampshire Oil Remediation and Compliance Bureau be submitted before a permit will be issued. This letter must state that the work will meet their requirements and they have issued a State permit for the work.

The Fire Official shall be notified not less than forty-eight (48) hours in advance so that they may witness:

- a. The tank has an approved identification label affixed to it.
- b. Air test before tank is placed in the ground.
- c. Air test with all connecting line in place and BEFORE tank(s) are covered.

WORK SHALL NOT BEGIN WITHOUT FIRST SECURING A PERMIT FROM THE BUREAU OF FIRE PREVENTION.

THIS IS NOT A PERMIT

A Permit Fee of \$50.00 shall be made payable to: Town of Hampton

Date of Application: _____ Date Work Will Begin: _____

Name of Property: _____

Address of Property: _____

Name of Company: _____

Address of Company: _____

Company Telephone #: _____ Fax #: _____

For Office Use Only:

Date Received: _____ Check #: _____ Permit #: _____

HFD/300-43

140 Winnacunnet Road Hampton, NH 03842



HAMPTON FIRE/RESCUE

A Tradition of Service, Courage and Pride

The following information and documentation must be provided with the application before a FLAMMABLE OR COMBUSTIBLE LIQUIDS UNDERGROUND STORAGE TANK PERMIT can be issued.

All work shall comply with NFPA 30 Flammable and Combustible Liquids Code and NFPA 1 Uniform Code (editions as adopted by NH Fire Code SAF-C-6000 and local ordinances)

UNDERGROUND STORAGE TANK	√
1. General description of proposed work.	
2. Copy of drawing indicating location, use, capacity and piping arrangement of all existing and proposed tank locations, or which are to be located upon the premises and all adjacent buildings and property lines.	
3. Letter from the New Hampshire Oil Remediation and Compliance Bureau before permit will be issued. Letter must state work will meet their requirements and they have issued a State permit for the work.	

The Fire Official shall be notified not less than forty-eight (48) hours in advance so they may witness:

- The tank has an approved identification label affixed to it
- Air test before tank is placed in the ground
- Air test with all connecting lines in place and BEFORE tank (s) are covered

140 Winnacunnet Road Hampton, NH 03842

www.hamptonfirerescue.com

Headquarters (603) 926-3316

Fax (603) 929-1915

Fire Prevention Fax (603) 926-8731